



Notes:

1. Trench width:

Minimum: Pipe O.D. + 12" (6" each side of pipe).

Maximum: 40" for 15"Ø pipe and smaller.

(1-1/2 x I.D.) + 18" for 18"Ø pipe and larger.

The neat-line payment limits for trench backfill materials shall be based upon the maximum allowable trench width as shown above.

2. Native material, if allowed for trench backfill, shall meet the requirements of select borrow per the Specifications. Trench backfill shall be compacted to a minimum of ninety-five percent (95%) of Modified Proctor in the Right-Of-Way and improved easements and to ninety percent (90%) in unimproved easement areas. See the Specifications for additional information.

3. Native material, if allowed for rigid pipe bedding, shall be sand and gravel with no material larger than 1-1/2". See the Specifications for additional information.

4. The neat-line limits shown will be used to calculate the maximum quantity of trench backfill and surface restoration materials allowed. Payment for bedding gravel will be considered incidental to payment made for pipe. Payment for foundation rock will be based upon the quantities used as directed by the District. See the Contract documents for additional information.

TYPICAL TRENCH SECTION & PAYMENT LIMITS

NOT TO SCALE

Detail Approvals
 Engineer GSM
 Manager DPK

NORTHSHORE UTILITY DISTRICT
STANDARD SEWER DETAILS

10

August 2011
 S-10(TypicalTrench w/Limits).dwg