



Notes:

1. Pipe anchors shall be installed on all slopes greater than 20% with spacing as follows:
 - A. Not greater than 36 ft. on grades from 20% to 35%.
 - B. Not greater than 24 ft. on grades from 35% to 50%.
 - C. Not greater than 16 ft. on grades greater than 50%.

PIPE ANCHOR

NOT TO SCALE

Detail Approvals
 Engineer GSM
 Manager DPK

NORTHSHORE UTILITY DISTRICT STANDARD SEWER DETAILS

12

August 2011
 S-12(PIPEANCHOR).DWG