



BACKFLOW ASSEMBLY TEST REPORT

PLEASE MAKE COPIES FOR ADDITIONAL ASSEMBLIES

NEW INSTALLATION SERVICE RESTORED Account # _____

MANUFACTURER	MODEL	SERIAL NO.	SIZE	PREMISE <input type="checkbox"/>
OWNER/CONTROLLER				IN PREMISE <input type="checkbox"/>
OWNER'S ADDRESS				
SERVICE ADDRESS				
LOCATION OF ASSEMBLY				
HAZARD ISOLATED <input type="checkbox"/> POTABLE WATER <input type="checkbox"/> IRRIGATION <input type="checkbox"/> FIRE <input type="checkbox"/> BOILER <input type="checkbox"/> _____				

R.P.B.A D.C.V.A. R.P.D.A. D.C.D.A. P.V.B.A. S.V.B.A.. AIR GAP

IS ASSEMBLY INSTALLED PROPERLY? YES NO COMMENTS _____

INITIAL TEST RESULTS	REDUCED PRESSURE ASSEMBLY	DOUBLE CHECK	P.V.B.A. / S.V.B.A		INITIAL TEST
		#1 CHECK PRESS DROP _____(A) RELIEF VALVE OPENED AT _____(B) min 2 psid BUFFER A-B= _____ min 3 psi RELIEF VALVE PASS <input type="checkbox"/> FAIL <input type="checkbox"/>	CHECK #1 TIGHT <input type="checkbox"/> _____ psid LEAKED <input type="checkbox"/> CHECK #2 TIGHT <input type="checkbox"/> _____ psid LEAKED <input type="checkbox"/>	AIR INLET OPENED AT _____ PSID DID NOT OPEN <input type="checkbox"/>	CHECK PRESS DROP _____ PSID FAILED <input type="checkbox"/>
REPAIRS AND/OR PARTS					
TEST AFTER REPAIRS	REDUCED PRESSURE ASSEMBLY	DOUBLE CHECK	P.V.B.A. / S.V.B.A		FINAL TEST
	#1 CHECK PRESS DROP _____(A) RELIEF VALVE OPENED AT _____(B) min 2 psid BUFFER A-B= _____ min 3 psi	CHECK #1 TIGHT <input type="checkbox"/> _____ psid CHECK #2 TIGHT <input type="checkbox"/> _____ psid	AIR INLET OPENED AT _____ PSID	CHECK PRESS DROP _____ PSID	PASSED <input type="checkbox"/> DATE: ____/____/____

IN COMPLETING AND SUBMITTING THIS TEST REPORT, THE TESTER CERTIFIES THE ASSEMBLY HAS BEEN TESTED AND MAINTAINED IN ACCORDANCE WITH ALL APPLICABLE RULES AND REGULATIONS OF NORTHSORE UTILITY DISTRICT AND THE STATE OF WASHINGTON.

TESTER SIGNATURE _____ TESTER NAME (PRINTED) _____ CERTIFICATION # _____

COMPANY _____ DETECTOR METER RDG _____

ADDRESS _____ PHONE # _____

Email reports to backflow@nud.net or fax to (425) 398-4432. Contact (425) 398-4417 or backflow@nud.net with questions.