



BACKFLOW ASSEMBLY TEST REPORT

PLEASE MAKE COPIES FOR ADDITIONAL ASSEMBLIES

NEW INSTALLATION SERVICE RESTORED Account # _____

MANUFACTURER	MODEL	SERIAL NO.	SIZE
OWNER/CONTROLLER			
OWNER'S ADDRESS			
SERVICE ADDRESS			
LOCATION OF ASSEMBLY			
HAZARD ISOLATED <input type="checkbox"/> POTABLE WATER <input type="checkbox"/> IRRIGATION <input type="checkbox"/> FIRE <input type="checkbox"/> BOILER <input type="checkbox"/> _____			

R.P.B.A D.C.V.A. R.P.D.A. D.C.D.A. P.V.B.A. S.V.B.A.. AIR GAP

IS ASSEMBLY INSTALLED PROPERLY? YES NO - COMMENTS _____

INITIAL TEST RESULTS	REDUCED PRESSURE ASSEMBLY		P.V.B.A. / S.V.B.A		INITIAL TEST
	#1 CHECK PRESS DROP _____ (A)	DOUBLE CHECK	AIR INLET	CHECK	PASSED <input type="checkbox"/> FAILED <input type="checkbox"/> DATE: _____/_____/_____ SYSTEM PSI _____
	RELIEF VALVE OPENED AT _____ (B) min 2 psid	TIGHT <input type="checkbox"/> _____ psid	OPENED AT _____	PRESS DROP _____	
	BUFFER A-B= _____ min 3 psi	LEAKED <input type="checkbox"/>	PSID _____	PSID _____	
	RELIEF VALVE PASS <input type="checkbox"/> FAIL <input type="checkbox"/>	CHECK #2 TIGHT <input type="checkbox"/> _____ psid	DID NOT OPEN <input type="checkbox"/>	FAILED <input type="checkbox"/>	
REPAIRS AND/OR PARTS					
TEST AFTER REPAIRS	REDUCED PRESSURE ASSEMBLY		P.V.B.A. / S.V.B.A		FINAL TEST
	#1 CHECK PRESS DROP _____ (A)	DOUBLE CHECK	AIR INLET	CHECK	PASSED <input type="checkbox"/> DATE: _____/_____/_____ SYSTEM PSI _____
	RELIEF VALVE OPENED AT _____ (B) min 2 psid	TIGHT <input type="checkbox"/> _____ psid	OPENED AT _____	PRESS DROP _____	
	BUFFER A-B= _____ min 3 psi	LEAKED <input type="checkbox"/>	PSID _____	PSID _____	

IN COMPLETING AND SUBMITTING THIS TEST REPORT, THE TESTER CERTIFIES THE ASSEMBLY HAS BEEN TESTED AND MAINTAINED IN ACCORDANCE WITH ALL APPLICABLE RULES AND REGULATIONS OF NORTHSORE UTILITY DISTRICT AND THE STATE OF WASHINGTON.

TESTER SIGNATURE _____ TESTER NAME (PRINTED) _____ CERTIFICATION # _____

COMPANY READING _____ DETECTOR METER _____

ADDRESS _____ PHONE # _____

Report can be faxed to (425) 398-4432 or e-mailed to backflow@nud.net