



#### NOTES:

1. PIPE ANCHORS SHALL BE INSTALLED ON ALL SLOPES GREATER THAN 20% WITH SPACING AS FOLLOWS:
  - A. NOT GREATER THAN 36 FT. ON GRADES FROM 20% TO 35%.
  - B. NOT GREATER THAN 24 FT. ON GRADES FROM 35% TO 50%.
  - C. NOT GREATER THAN 16 FT. ON GRADES GREATER THAN 50%.
2. IF CARRIER PIPE IS INSTALLED IN CASING PIPE, INSTALL FLANGE OR BRACKET TO SECURE PIPE ANCHOR TO CASING PIPE.

## PIPE ANCHOR

NOT TO SCALE

#### DETAIL APPROVALS

EDITOR TMC

ENG. DIR. SJD

## NORTHSHORE UTILITY DISTRICT

### 2025 STANDARD SEWER DETAILS

**13**

LAST UPDATED  
FEBRUARY 2020