CODES WATER 4" JUNCTION- BOX INFLUENT HUB FOR PIPING (4" STANDARD) FROM THE HOUSE 2' MIN 12" MIN 6" MIN 6" SP	SWITCH CONCRETE ANCHOR NEMA 3 WEATHERPROOF PANEL, WALL MOUNTED FLASHING RED LIGHT MIN BEDDING MATERIAL, PER THE RINDER PUMP PROFILE	NG"
NOTES:		1" CONDUIT TO WET WELL [L
	O COMPLETE PACKAGED SEWER GRINDER LIFT STATION PRO SYSTEM) TO INCLUDE THE FOLLOWING:	
1. GRINDER PUMP AT 5" IMPELLER	WITH 2HP SUBMERSIBLE SINGLE PHASE MOTOR (ADEQUATE FOR SINGLE RESIDENCE UP DIA.)	TO 100' HEAD
	DAT TYPE MERCURY SWITCHES FOR LEVEL CONTROL	
	CH FOR ALARM CONTROL DINDUIT OUTSIDE OF SUMP FOR CONTROL WIRING	
 T NET MALE CONDUCTION OUTSIDE OF SOME FOR CONTROL WIRING DISCHARGE PIPING SHALL INCLUDE A CHECK VALVE, A GATE VALVE AND NPT FEMALE CONNECTION OUTSIDE OF SUMP (DIA. PER PRESSURE PIPE DIA.) 		
,	SURE PIPE DIA.) SHALL PROVIDE HUB FOR PVC PIPE OUTSIDE OF SUMP (DIA. PER SIDESEWER DIA.)	
7. FIBERGLASS SUMP BASIN 24" I.D. x 5'-0" HIGH (PER BULLETIN SPG-604 (HYDROMATIC OR EQUAL))		
8. NEMA 3R LOCKING CONTROL PANEL WITH GENERATOR HOOK-UP, MOUNTED OUTSIDE ON HOUSE WALL		
9. RED ALARM LIGHT PANEL, MOUNTED OUTSIDE ON HOUSE WALL 10. SEE ADDITIONAL INFORMATION PER STANDARD SEWER DETAIL 14d GENERAL NOTES		
SINGLE FAMILY GRINDER PUMP STATION		
HYDROMATIC		
DETAIL APPROVALS		
EDITOR TMC		14a
MANAGER SJD	2022 STANDARD SEWER DETAILS	LAST UPDATED APRIL 2021