



NOTES:

1. TRENCH DAMS ARE TO BE INSTALLED IN HIGH GROUND WATER AREAS SUCH AS ADJACENT TO WETLANDS, STREAMS, AS SHOWN ON APPROVED PLANS, OR AS DIRECTED BY THE DISTRICT.
2. TRENCH DAMS ARE TO BE PLACED 5' UPSTREAM FROM MANHOLES AND AS DIRECTED BY THE DISTRICT.
3. ELEVATION AT TOP OF TRENCH DAM TO VARY BASED ON WATER TABLE.
4. SLOPE OF THE TRENCH DAM IS TYPICALLY 3:1.

TRENCH DAM

NOT TO SCALE

DETAIL APPROVALS

EDITOR *TMC*

ENG. DIR. *CF*

NORTHSHORE UTILITY DISTRICT
2025 STANDARD SEWER DETAILS

16

LAST UPDATED
MAY 2025