



NOTES:

1. ALL CLEANOUTS SHALL BE BROUGHT TO GRADE AND INSTALLED IN A CLEANOUT BOX AND PLUGGED WATERTIGHT WITH A MECHANICAL PLUG, PER STANDARD SEWER DETAIL #9 AND #9a. A 4" 2-WAY TEST TEE MAY BE USED AT THE HOUSE CONNECTION IN LIEU OF A WYE.
2. CLEANOUTS IN HARDSCAPE (SUCH AS SIDEWALKS, DRIVEWAYS, AND PATIOS) AND AT EDGE OF R.O.W. OR EASEMENT REQUIRE A CAST IRON CLEANOUT BOX. FOR CLEANOUTS NOT IN HARDSCAPE AREAS, THE CLEANOUT CAN BE INSTALLED IN A LANDSCAPE/IRRIGATION BOX. SEE STANDARD SEWER DETAIL #9a FOR CLEANOUT BOX REQUIREMENTS.
3. ALL PIPE MATERIAL SHALL BE BELL & SPIGOT TYPE WITH RUBBER GASKET JOINT AND SHALL BE IN CONFORMANCE WITH ASTM D3034 (SDR-35).

SIDE SEWER HOUSE CONNECTION

NOT TO SCALE

DETAIL APPROVALS

EDITOR TMC

ENG. DIR. CF

NORTHSHORE UTILITY DISTRICT
2025 STANDARD SEWER DETAILS

8b

LAST UPDATED
MAY 2025