



MATERIALS LIST

ITEM DESCRIPTION

- (A) STAINLESS STEEL TAPPING TEE WITH DI FLANGE; ROMAC SST, FORD FAST, OR JCM 462.
- (B) PRECAST 4"x8"x16" CONCRETE BLOCK.
- (C) R.W. GATE VALVE, F.L.xR.J.: SHALL BE PER THE SPECIFICATIONS. FOR VALVE OPERATING NUT DEPTHS, SEE STANDARD WATER DETAIL #11
- (D) TWO-PIECE VALVE BOX AND ETHAFOAM RING PER THE SPECIFICATIONS AND STANDARD WATER DETAIL #11.
- (E) TRACER WIRE: DIRECT BURY BLUE 14 GAUGE COPPER, CONTINUOUS, SOLID CORE, POLYETHYLENE INSULATED WIRE PER THE SPECIFICATIONS. CONTINUOUS FROM MAINLINE.

TAPPING TEE AND GATE VALVE

NOT TO SCALE

DETAIL APPROVALS

EDITOR TMC

ENG. DIR. SJD

NORTHSHORE UTILITY DISTRICT

2025 STANDARD WATER DETAILS

20

LAST UPDATED
JANUARY 2023