



### MATERIALS LIST

#### ITEM QTY. DESCRIPTION

- |   |   |  |
|---|---|--|
| ① | 1 | TAPPED & THREADED D.I. CAP, RJ WITH 2" IP TAP.   |
| ② | 2 | 2" GALVANIZED PIPE, LENGTH TO FIT.               |
| ③ | 1 | 2" 90° GALVANIZED ELBOW, FIPxFIP.                |
| ④ | 1 | 2" BALL VALVE, FIPxFIP, MATCO 757T08LF OR EQUAL. |
| ⑤ | 1 | TRAFFIC RATED BOX AND COVER, OR EQUAL.           |

### NOTES:

1. NUMBER AND LOCATION OF THE TEMPORARY BLOW-OFFS WILL BE AS SHOWN ON THE DESIGN PLANS OR AS DIRECTED BY THE DISTRICT IN THE FIELD.
2. PROVIDE TEMPORARY BLOCKING FOR BLOW-OFFS TO RESIST TEST PRESSURES.

## **TEMPORARY BLOW-OFF ASSEMBLY FOR NEW WATERMAIN**

NOT TO SCALE

### DETAIL APPROVALS

**EDITOR** TMC

**ENG. DIR.** SJD

## **NORTHSHORE UTILITY DISTRICT**

### **2025 STANDARD WATER DETAILS**

**17**

LAST UPDATED  
FEBRUARY 2020