



MATERIALS LIST

ITEM QTY. DESCRIPTION

- | | | |
|---|---|--|
| ① | 1 | TAPPED & THREADED D.I. CAP, RJ WITH 2" IP TAP. |
| ② | 2 | 2" GALVANIZED PIPE, LENGTH TO FIT. |
| ③ | 1 | 2" 90° GALVANIZED ELBOW, FIPxFIP. |
| ④ | 1 | 2" BALL VALVE, FIPxFIP, MATCO 757T08LF OR EQUAL. |
| ⑤ | 1 | TRAFFIC RATED BOX AND COVER, OR EQUAL. |

NOTES:

1. NUMBER AND LOCATION OF THE TEMPORARY BLOW-OFFS WILL BE AS SHOWN ON THE DESIGN PLANS OR AS DIRECTED BY THE DISTRICT IN THE FIELD.
2. PROVIDE TEMPORARY BLOCKING FOR BLOW-OFFS TO RESIST TEST PRESSURES.

TEMPORARY BLOW-OFF ASSEMBLY FOR NEW WATERMAIN

NOT TO SCALE

DETAIL APPROVALS

EDITOR TMC

MANAGER SJD

NORTHSHORE UTILITY DISTRICT

2022 STANDARD WATER DETAILS

17

LAST UPDATED
FEBRUARY 2020